

OVERHEAD FARM SERVICE

NOTE:

1. CUSTOMER POLE HEIGHT AND LOCATION TO BE APPROVED BY COOPERATIVE.
2. GROUND CLEARANCE SHOULD EXCEED NESC MINIMUMS, TO THE EXTENT PRACTICAL, TO ENSURE COMPLIANCE UNDER ALL LOADING CONDITIONS THROUGHOUT THE LIFE OF THE INSTALLATION. SERVICE LINES WHICH ARE NOT ENGINEERED AND SAGGED DURING INSTALLATION SHOULD NOT EXCEED 75' IN LENGTH AND MEASURED GROUND CLEARANCE SHOULD EXCEED NESC MINIMUM LOCATION REQUIREMENTS BY 12".
3. SERVICE NEUTRAL AND METER BASE MUST BE PERMANENTLY GROUNDED IN ACCORDANCE TO THE NEC.
4. RACK, HOUSE KNOB, OR EYEBOLT (ATTACHMENT HEIGHT) MUST PROVIDE A MINIMUM HEIGHT OF 12' OVER RESIDENTIAL DRIVEWAYS AND 16' OVER COMMERCIAL/DRIVEWAYS SUBJECT TO TRUCK TRAFFIC.
5. CUSTOMER FACILITIES TO BE INSTALLED IN ACCORDANCE WITH ALL NATIONAL, STATE, AND LOCAL CODES.
6. ALL MATERIALS AND EQUIPMENT, WITH EXCEPTION OF SERVICE DROP, ATTACHMENT CLAMP, SERVICE ENTRANCE CONNECTIONS, AND ELECTRIC METER ARE TO BE PROVIDED AND INSTALLED BY THE CUSTOMER/CONTRACTOR.
7. *GROUND ROD AT METER PEDESTAL IS SHOWN BELOW GRADE. ALWAYS INSTALL PER MOST STRINGENT CODE (NATIONAL, STATE, LOCAL).

