UNDERGROUND MOBILE HOME SERVICE

MATERIAL AND INSTALLATION:

- 1. COOPERATIVE WILL PROVIDE AND INSTALL THE ELECTRIC METER.
- 2. CONTRACTOR MUST INSTALL AN APPROVED, RINGLESS DESIGN METER BASE.
- 3. ALL MATERIAL IS TO BE FURNISHED AND INSTALLED BY THE CONTRACTOR IN CONFORMANCE WITH ALL NATIONAL AND LOCAL CODES.

REQUIREMENTS:

- 1. ALL HARDWARE MUST BE RIGIDLY ATTACHED TO POLE.
- 2. ALL BOXES AND FITTINGS MUST BE WEATHERPROOF.
- 3. COPPER SERVICE WIRE REQUIRED (MIN. #2 FOR 100A AND 2/0 FOR 200A)
- 4. THIN-WALLED CONDUIT IS NOT ACCEPTED. RIGID OR SCH 80 ONLY.
- 5. FUSE OR BREAKER DISCONNECT IMMEDIATELY AFTER METER BASE.
- 6. 5/8" X 8' GROUND ROD WITH #6 (MIN.) BARE COPPER GROUND WIRE SECURELY ATTACHED.

UNDERGROUND SERVICE NOTE:

PLEASE REFER TO UNDERGROUND PERMANENT SERVICE CONDUIT INFORMATION SHEET FOR MORE INFORMATION REGARDING UNDERGROUND FROM NORTHCENTRAL FACILITY TO METER BASE.

